

GOVERNMENT OF TELANGANA
DEPARTMENT OF WATER AND WASTE WATER EXAMINATION
Directorate of I.P.M, P.H. Labs, Food (H) Administration, Narayanaguda.

REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER

1. Sample From: G.Pulla Reddy Memorial School, H.No:9-118/1, Lalitha Nagar, Dilsuknagar, HydTG.

2. Collected by: Party

3. Collected on : 15-07-2026

4. Received on: 15-07-2026

Lab. Ref. No.	Source	Exact location	Residual Chlorine mg per liter	Total coliform bacteria (MPN Index) per 100ml	Faecal coliform bacteria per 100ml	Esch. coli per 100ml	Result
8085	R.O water	Direct R.O water		Nil			Satisfactory
8086	R.O water (TPC)	Direct R.O water	Total Aerobic Bacterial Plate Count for 24 hrs at 37°C = 20 CFU / ml				Satisfactory
8088	Borewell water	Direct Borewell water		9	Absent	Absent	Unsatisfactory due to presence of coliform bacteria

Remarks: The sample was submitted by the party and was not collected by laboratory personnel. Hence, the results pertain only to the sample as received. The laboratory does not take responsibility for the source, representativeness, or integrity of the sample.

[Signature]
Dy. Chief Water Analyst
Institute of Preventive Medicine
Public Health Labs & Food (H) Admn.
Narayanaguda, Hyderabad-29, T.S.